

Bacharachガス検出器と対象ガス、検出範囲(2/4)

検出器名 ガス名	MGS-400			MGS-250			MGS-550			MVR-300			HGM-SZ/MZ			HGM-SZ/MZ			Chillgard 5000		
	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲
R113													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R114													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R123													○	IR	0-10,000ppm				○	IR	0-1,000ppm
R124													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R125													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R134a	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm				○	IR	0-1,000ppm
							○	SC	0-10,000ppm												
R143A																			○	IR	0-1,000ppm
R152A																			○	IR	0-1,000ppm
R218																			○	IR	0-1,000ppm
R227													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R236FA													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R245FA													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R290							○	SC	0-5,000ppm												
R401A													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R402A													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R402B													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R404A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm	○	SC	0-2,500ppm	○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
							○	SC	0-10,000ppm	○	SC	0-5,000ppm									
R404A										○	SC	0-10,000ppm									
R407A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
							○	SC	0-10,000ppm												
R407C				○	IR	0-3,500ppm	○	SC	0-1,000ppm	○	SC	0-2,500ppm	○	IR	0-10,000ppm				○	IR	0-1,000ppm
							○	SC	0-10,000ppm	○	SC	0-5,000ppm									
										○	SC	0-10,000ppm									
R407F	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
							○	SC	0-10,000ppm												
R408A													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R409A													○	IR	0-10,000ppm	○	IR	0-10,000ppm			

Bacharachガス検出器と対象ガス、検出範囲(3/4)

検出器名 ガス名	MGS-400			MGS-250			MGS-550			MVR-300			HGM-SZ/MZ			HGM-SZ/MZ			Chillgard 5000		
	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	センサー	検出範囲
R410A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm	○	SC	0-2,500ppm	○	IR	0-10,000ppm				○	IR	0-1,000ppm
							○	SC	0-10,000ppm	○	SC	0-5,000ppm									
										○	SC	0-10,000ppm									
R422	○	SC	0-1,000ppm		IR																
R422A				○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
							○	SC	0-10,000ppm												
R422D	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
							○	SC	0-10,000ppm												
R424A													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R426A													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R427A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R434A	○	SC	0-1,000ppm		IR																
R438A													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R448A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R449A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R452A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R452B	○	SC	0-1,000ppm	○	IR	0-3,500ppm							○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R454A	○	SC	0-1,000ppm		IR										○	IR	0-10,000ppm				
R454B	○	SC	0-1,000ppm		IR														○	IR	0-1,000ppm
R454C	○	SC	0-1,000ppm		IR										○	IR	0-10,000ppm				
R455A	○	SC	0-1,000ppm		IR										○	IR	0-10,000ppm	○	IR	0-1,000ppm	
R466A																			○	IR	0-1,000ppm
R500													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R502													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R503													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
R507A	○	SC	0-1,000ppm		IR														○	IR	0-1,000ppm
R507	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm			
							○	SC	0-10,000ppm												
R508B													○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R513A	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R514A				○	IR	0-3,500ppm							○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm

Bacharachガス検出器と対象ガス、検出範囲(4/4)

検出器名 ガス名	MGS-400			MGS-250			MGS-550			MVR-300			HGM-SZ/MZ			HGM-SZ/MZ			Chillgard 5000		
	設定	センサー	検出範囲	設定	センサー	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲	設定	セン サ	検出範囲
R515B																			○	IR	0-1,000ppm
R1224YD(Z)														○	IR	0-10,000ppm					
R1233ZD				○	IR	0-3,500ppm							○	IR	0-10,000ppm				○	IR	0-1,000ppm
R1233ZDE																					
R1234ZE	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm	○	IR	0-10,000ppm	○	IR	0-1,000ppm
R1234YF	○	SC	0-1,000ppm	○	IR	0-3,500ppm	○	SC	0-1,000ppm				○	IR	0-10,000ppm				○	IR	0-1,000ppm
R1234ZE							○	SC	0-10,000ppm												
R-1336E																○	IR	0-10,000ppm			
R-1336Z																○	IR	0-10,000ppm			
Butane (R600)							○	IR/CT	0-100 %LEL												
Methane (R50)							○	IR/CT	0-100 %LEL												
Propane (R290)							○	IR/CT	0-100 %LEL												
LPG							○	CT	0-100 %LEL												
NH3 (R717)							○	SC	0-10,000ppm												
Butane (R600)							○	SC	0-5,000ppm												
Ethylene							○	SC	0-2,000ppm												
FA188													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
FC72													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
FC3284																○	IR	0-10,000ppm			
H1211													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
H1301													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
H2402													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
HFP													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
N1230													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
N5110																○	IR	0-10,000ppm			
N4710													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
N7100													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
N7200													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
N7300													○	IR	0-10,000ppm	○	IR	0-10,000ppm			
N7600													○	IR	0-10,000ppm	○	IR	0-10,000ppm			